



TC-7183
IILR : TC718324000003453F

Office
1-4, First Floor, Mukund House,
Azadpur, Delhi-110033
T: 011 48018197 | M: +91 9871143785

Laboratory
Plot No. 43, HSIDC Indl Estate,
Raj, Sonapat, Haryana-131020
T: 0130 4017631 | M: +91 9215515652

Email/Website
info@metl.co.in
metl@metl.co.in
www.metl.co.in

TEST REPORT

Page No. 1/1

Report No: METL/26-27/352/053		Report Date	22-04-2026
Issued To:		Customer Reference	N.A.
Amrita Public School		Date of Sample Received	20-04-2026
K-2, Sangam Vihar, New Delhi-110080		Date of test start	20-04-2026
		Date of Completion of test	22-04-2026
Sample Name	Water		
Sample Description	Drinking Water		
Sampling Location	-		
Sample Submitted By	Customer	Date of Sampling	20-04-2026
Sampling Method	N.A.	Packing	Plastic Bottle
Environmental Condition	22 Deg C	Sample Quantity	1 Ltr.
Group Name	Water	Discipline	Chemical

TEST RESULT

S.No.	Test Parameter	Unit	Observed Value	Requirement as per IS: 10500-2012 RA 2018		Test Method
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source	
Chemical Test						
1	Colour	Hazen	<5	5.0 Max	15 Max	IS 3025(Pt-4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025(part 5):2018
3	Turbidity	NTU	0.23	1.0 Max	5 Max	IS 3025(Pt-10):2023
4	pH Value (at 25°C)	-	6.57	6.5-8.5	No relaxation	IS 3025(Pt-10):2022
5	Total Hardness (as CaCO ₃)	mg/l	BDL(DL-2.0)	200 Max	600 Max	IS 3025(Pt-21):2009 RA 2019
6	Chloride (as Cl)	mg/l	12	250 Max	1000, Max	IS 3025(Pt-32):1988 RA 2019
7	Total Dissolved Solids	mg/l	82	500 Max	2000, Max	IS 3025(Pt-16):2023
8	Residual Free Chlorine	mg/l	Nil	0.2 Min	1.0 Min	IS 3025(Pt-26):2021
9	Iron (as Fe)	mg/l	0.08	1.0 Max	No Relaxation	IS 3025(Pt-53):2024
10	Fluoride (as F)	mg/l	0.11	1.0 Max	1.5 Max	APHA 24th Edi. 2023(4500 F)

Remarks: The Submitted sample conforms to IS: 10500-2012 RA 2018 w.r.t. above tests.

End of Report

Chhotu Ram
Technical Manager
Checked by

AMRITA PUBLIC SCHOOL

PRINCIPAL

MANAGER



Moshood,
Quality Manager
Authorized Signatory

Terms & Conditions

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied
- Total liability of our lab is limited to the invoiced amount
- Samples will be destroyed after 30 Days from the date of issue of test report.
- This report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any other way without our written permission in writing



Scanned with OKEN Scanner



MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016

17/06/26
17/06/26
17/06/26

NO. DHIO/SZ/MCD/2026/D-492.

Dated: 17.06.26.

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Harish Chand Bairwa, Assistant Public Health Inspector from Public Health Department, South Zone inspected of Amrita Public School located at K-2/474, Sangam Vihar, New Delhi- 110080 found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

If Building Department or any other Government Agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

Copy to:-

The Principal

Amrita Public School
K-2/474, Sangam Vihar,
New Delhi- 110080.

Office Copy

17/06/26
Deputy Health Officer
South Zone
Dy. Health Officer
South Zone, MCD

AMRITA PUBLIC SCHOOL

Gita Goyal
PRINCIPAL

Manager
MANAGER